

ADDENDUM NO. 1
to the
Sally Ann Creek AOP Crossing #1
Culvert Replacement
Nez Perce Tribe – Dated: 2/4/2025

This addendum dated February 4, 2025, is for all persons preparing bids for the above-named project and as such shall be made a part of Contract Documents.

All changes, corrections, deletions, and/or additions to the initial bidding documents enumerated herein shall be included in the Bidders Proposal. In case of any conflict between the drawings, specifications, and this Addendum, this Addendum shall govern.

The bidders shall acknowledge the receipt of this Addendum.

Found below are some points of clarification regarding the upcoming 2025 construction contract.

1. Proposals are due on Monday, February 17; however, this is a federal holiday. Proposals will now be due by 4:00 pm on Tuesday, February 18, 2025.
2. Special Provisions includes provisions for a precast concrete 3-sided box culvert (page 19) in addition to the structural steel arch plate culvert called for in the design plans. The Special Provisions was drafted for more than one crossing in a design package. Please disregard any reference to crossings other than what is included in the design plans and RFP, a 19'-0" span x 6'-4" rise structural steel plate arch.
3. In addition to coordination with the upstream construction site to reduce the length of time Sally Ann Creek Road is closed, contractors will need to coordinate closure times as to not restrict haul times and routes for one another. Applicants are encouraged to include a coordination plan to detail how to coordinate scheduling with the upstream construction project.